

# CITY OF LOS ANGELES

CALIFORNIA



ANTONIO R. VILLARAIGOSA  
MAYOR

**BOARD OF  
BUILDING AND SAFETY  
COMMISSIONERS**

EFREN ABRATIQUE, P.E.  
PRESIDENT

JAVIER NUÑEZ  
VICE-PRESIDENT

MARSHA L. BROWN

ILAN ISRAELY  
WILLIAM J. ROUSE

**DEPARTMENT OF  
BUILDING AND SAFETY**  
201 NORTH FIGUEROA STREET  
LOS ANGELES, CA 90012

ANDREW A. ADELMAN, P.E.  
GENERAL MANAGER

RAYMOND CHAN  
EXECUTIVE OFFICER

Trilogy Materials, Ltd.  
5776 N. Mesa Street  
El Paso, Texas 79912

Attn: Ron Hicks  
(702) 438-4455

RESEARCH REPORT: RR 25572  
(CSI # 03100)

BASED UPON ICC EVALUATION SERVICE  
LEGACY REPORT NO. ER- 5949

REEVALUATION DUE DATE:  
November 1, 2007

**GENERAL APPROVAL** - Reevaluation - Perform Wall® Panel System.

## **DETAILS**

The above products are approved under the description, identification and findings in Legacy Report No. ER-5949 dated July 1, 2003, of the ICC Evaluation Service, Incorporated. The report, in its entirety, is attached and made part of this general approval.

The parts of Legacy Report No. ER-5949 marked by the asterisks are deleted by the Los Angeles Building Department from this approval.

### **The approval is subject to the following conditions:**

1. Complete design and calculation shall be prepared by an engineer licensed in the State of California and approved by the structural plan check.
2. The form work shall be used in areas where combustible material are permitted by the codes.
3. The maximum allowable pour rate of the forms shall be 4 feet per hour.
4. Alternate design shall comply with Prescriptive Method for Insulating Concrete Forms in Residential construction (PCA publication No. ER 118), dated May 1998, subject to all

RR 25572  
Page 1 of 2

Trilogy Materials, Ltd.  
Re: Perform Wall® Panel System

applicability limits of Table 1.1 contained therein. The PCA document must be available to structural plan check upon request.

5. Continuous inspection by Deputy Inspectors shall be provided during the taking of test specimens and the placing of reinforced concrete. Any exception shall be approved by structural plan check supervisors.

## **DISCUSSION**

The approval is based on tests and analyses.

The status of the referenced Legacy Report No. ER-5949 dated July 1, 2003, which is currently beyond its re-examination date is still valid. The validity of the Legacy Report was verified with ICC.

This general approval will remain effective provided the Evaluation Report is maintained valid and unrevised with the issuing organization. Any revisions to the report must be submitted to this Department, with appropriate fee, for review in order to continue the approval of the revised report.

This general approval of an equivalent alternate to the Code is only valid where an engineer and/or inspector of this Department has determined that all conditions of this Approval have been met in the project in which it is to be used.

Addressee to whom this Research Report is issued is responsible for providing copies of it, complete with any attachments indicated, to architects, engineers and builders using items approved herein in design or construction which must be approved by Department of Building and Safety Engineers and Inspectors.

YEUAN CHOU, Chief  
Engineering Research Section  
2319 Dorris Place  
Los Angeles, CA 90031  
(213) 485-2376

YC/elem  
RR25572/wp8.0  
R11/14/05  
2C/1910.10/1914.4/1921.6

Attachments: ICC Legacy Report No ER-5949 (9 pages)